

島根原子力発電所 沿岸定点の水温 (平成25年5月)

観測時刻 10 時

場 所	日 水 深	(単位: °C)																																	
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	水深別 平均	月 間 最高 最低	
1号機放水口	1m	15.6	15.5	15.7	15.8	15.8	16.0	16.2	16.1	15.9	16.4	16.3	16.6	16.8	17.0	16.9	17.5	17.5	16.4	16.5	17.0	17.7	17.8	18.2	18.2	18.3	18.3	18.2	17.8	18.5	19.3	19.8	17.1	19.8 15.5	
	2m	16.0	15.9	15.9	16.0	16.0	16.4	16.5	16.4	16.4	17.0	17.0	16.9	17.3	17.5	17.3	18.2	17.8	16.7	16.7	17.4	17.9	18.4	18.4	18.6	18.7	18.5	18.5	18.4	18.7	19.4	20.2	17.5	20.2 15.9	
	4m	16.0	16.0	15.9	16.0	16.2	16.4	16.5	16.7	16.6	16.8	16.9	17.3	17.7	17.7	17.7	18.1	17.8	17.1	17.0	17.6	18.3	18.7	18.6	18.7	19.0	19.2	19.1	18.8	19.3	20.0	20.8	17.7	20.8 15.9	
輸 谷 湾	1m	15.4	15.4	15.8	15.9	15.8	16.2	16.2	16.1	16.5	16.4	16.4	16.9	17.2	17.1	17.6	17.6	16.9	16.9	17.0	17.7	18.2	18.4	18.4	18.7	18.7	18.6	18.6	18.4	19.0	19.8	17.2	19.8 15.4		
	3m	15.4	15.3	15.7	15.8	15.7	16.0	16.1	16.0	16.0	16.4	16.3	16.3	16.8	17.0	16.9	17.6	17.5	16.5	16.7	16.8	17.7	17.9	18.2	18.2	18.4	18.4	18.5	18.3	17.9	18.3	19.0	19.7	17.1	19.7 15.3
	1m	15.0	15.1	15.2	15.4	15.4	15.7	15.6	15.6	15.8	16.0	15.9	16.1	16.5	16.8	16.8	17.3	17.0	16.8	16.6	16.8	17.5	17.8	18.0	18.1	18.6	18.5	18.3	18.1	18.1	18.6	19.3	16.9	19.3 15.0	
片 匂	3m	15.2	15.2	15.4	15.6	15.5	15.8	15.7	15.8	15.9	16.2	16.1	16.6	16.9	16.8	17.4	17.2	16.8	16.5	16.7	17.4	17.6	17.9	18.0	18.2	18.2	18.4	18.3	18.1	18.1	18.6	19.3	16.9	19.3 15.0	
	1m	15.6	15.2	16.0	16.1	16.1	16.6	16.7	16.6	16.2	16.7	16.6	16.6	17.3	17.6	17.5	18.1	18.0	17.2	17.1	17.8	18.5	18.7	18.8	18.8	18.9	19.2	19.2	18.2	18.0	18.7	19.7	17.4	19.7 15.2	
	3m	15.8	15.4	16.0	16.1	16.1	16.5	16.6	16.5	16.2	16.8	16.7	16.6	17.1	17.6	17.4	18.1	17.8	16.8	16.8	17.0	17.7	18.4	18.6	18.5	18.6	18.7	18.8	18.0	18.1	18.8	19.4	17.3	19.4 15.4	

場 所	日 水 深	月 間										
		上 旬 (7日)	中 旬 (13日)	下 旬 (21日)	水深別 平均	最高	最低					
※ 放水口沖 (1号)	0m	16.0	17.2	17.9	17.0	17.9	16.0					
	1m	16.0	17.1	17.9	17.0	17.9	16.0					
	2m	16.0	17.0	17.8	16.9	17.8	16.0					
	3m	16.0	16.9	17.7	16.9	17.7	16.0					
	4m	16.0	16.9	17.7	16.9	17.7	16.0					
	5m	16.0	16.9	17.7	16.9	17.7	16.0					
	6m	16.0	16.8	17.7	16.8	17.7	16.0					
	7m	16.0	16.8	17.7	16.8	17.7	16.0					
	8m	16.0	16.8	17.7	16.8	17.7	16.0					
	9m	15.9	16.7	17.7	16.8	17.7	15.9					
10m	15.9	16.7	17.7	16.8	17.7	15.9						

※ 放水口沖水温は、可搬式水温計による実測値。